

GLENDALE FIRE DEPARTMENT INSPECTION REPORT

- ☒ 1st Notice
☐ 2nd Notice
☐ Final Notice

File 4634 Recheck 7-14-86 Date 6-30-86 Occupancy Class B-2 Inspection Area 28
 Location 638 SAN FERNANDO RD. Firm Name PENNDYER DODGE
 Building Owner HAZEL DODGE Manager/Lessee HAZEL DODGE
 Address _____ Address 23366 LOS ENCINOS
 City _____ Tel. _____ City WOODLAND HILLS Tel. 992-5659
 Contacted WALLY BLOHM Title _____
 REASONABLE FIRE SAFETY EXISTS THIS DATE 7/14/86 Inspector [Signature]

YOUR ATTENTION IS CALLED TO THE FOLLOWING VIOLATIONS OF THE ☐ UNIFORM FIRE CODE, ☐ UNIFORM BUILDING CODE, ☐ GLENDALE MUNICIPAL CODE, ☐ TITLE 19 C.A.C., ☐ _____

NOTE: VIOLATIONS ARE INDICATED BY CHECK MARKS ADJACENT TO NUMBERS

- ☐ 1. Provide _____ minimum _____ fire extinguisher(s) in a conspicuous and accessible location. Extinguisher(s) shall be U.L. approved and have the State Fire Marshal's Certification Tag attached.
- ☒ 2. Have your extinguisher(s) serviced by a qualified and licensed fire extinguisher concern in accordance with Title 19, C.A.C. This shall be done on a yearly basis. UPSTAIRS WATER CAN.
- ☐ 3. Provide a complete test of the _____ system(s) within the building. All repairs and tests shall be made in accordance with recognized standards. ☐ Tests shall be witnessed by a fire department representative.
- ☒ 4. Remove temporary and unapproved electrical wiring from _____
 - ☐ a. Install cover plates on all electrical outlets and junction boxes.
 - ☐ b. Eliminate all multiple connections.
 - ☐ c. Repair/replace defective or unapproved electrical cords/wiring.
- ☐ 5. It is unlawful to block open stairway and/or fire doors.
- ☐ 6. Immediately remove obstruction(s) to means of egress.
- ☐ 7. Repair exit door(s). Doors provided for egress shall be maintained.
- ☐ 8. Repair all holes in walls and/or ceilings.
- ☐ 9. Establish adequate aisles and passageways not less than _____ wide and keep same free and clear at all times.
- ☒ 10. Remove combustible storage/materials from/within 3 ft of ELECTRICAL PANELS
- ☐ 11. Post a sign(s) indicating _____
- ☐ 12. A general cleanup of the premises is indicated at this time.
- ☐ 13. Provide metal containers with tight-fitting lids for:
 - ☐ a. Collection and storage of oily and greasy rags.
 - ☐ b. Storage of all combustible rubbish and provide adequate pick-up service.
- ☐ 14. Provide an address on the front of the building that is clearly visible from street.
- ☐ 15. Apply at the Fire Prevention Bureau, 633 East Broadway, Room 303, Telephone (818) 956-4810 for a permit to: _____
- ☐ 16. Additional requirements and/or remarks _____

NOTE: FOR ADDITIONAL REQUIREMENTS AND/OR REMARKS, SEE ATTACHED SECOND PAGE.

A REINSPECTION OF THE PREMISES WILL BE MADE IN APPROXIMATELY 14 DAYS FROM THE ABOVE DATE, AT WHICH TIME WE SHALL EXPECT SUBSTANTIAL COMPLIANCE WITH THESE REQUIREMENTS.

This inspection was conducted by: [Signature] Inspector _____

- ☐ Engine Company _____
- ☒ Truck Company 16 B
- ☐ Fire Prev. Bureau _____
- Tel. No. (818) 956-4026

☐ Reasonable Fire Safety Exists At This Time

☐ Violation Cleared

☐ Referred to Fire Prevention Division

COMPANY RESPONSIBILITIES

☐ Reinspection (Date) _____ Inspector _____

☐ Second Notice (Date) _____ Inspector _____

☐ Reinspection (Date) _____ Inspector _____

☐ Sent To Fire Prevention Bureau (Date) _____ Inspector _____

Comments _____

FIRE PREVENTION RESPONSIBILITIES

☐ Reinspection (Date) _____ Inspector _____

☐ Final Notice (Date) _____ Inspector _____

☐ Reinspection (Date) _____ Inspector _____

☐ Sent To City Attorney (Date) _____ Inspector _____

☐ Office Hearing (Date) _____ Inspector _____

☐ Reinspection (Date) _____ Inspector _____

☐ Court (Div. and Date) _____

Comments _____